AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 01-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	24-09-2020
Sample Type	C C Drain Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	01-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	451	14.58	14.68
2	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	449	14.23	
3	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	454	15.23	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP. Bangalore - 92

AARTN ASSOCIATES
DATE
BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 01-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	24-09-2020
Sample Type	C C Drain Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	01-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	451	14.58	15.08
2	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	449	14.68	
3	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	454	15.97	

Remarks :

AARTN ASSOCIATES DATE BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 01-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	24-09-2020
Sample Type	C C Drain Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	01-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	451	14.27	15.31
2	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	449	15.68	
3	C C Drain Wall Concrete	M20	24-09-2020	01-10-2020	150x150x150	22500	454	15.97	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES DATE BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 09-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	2-10-2020
Sample Type	R C C Raft Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	09-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	452	14.65	14.97
2	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	450	15.62	
3	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	455	14.65	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES DATE BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 09-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	2-10-2020
Sample Type	R C C Raft Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	09-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	452	14.52	14.50
2	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	450	14.32	
3	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	455	14.65	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 09-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	2-10-2020
Sample Type	R C C Raft Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	09-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	452	14.52	14.74
2	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	450	14.32	
3	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	455	15.37	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP. Bangalore - 92

AARTN ASSOCIATES DATE No. BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 09-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	2-10-2020
Sample Type	R C C Raft Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	09-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	452	14.13	14.91
2	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	450	15.24	
3	R C C Raft Culvert	M20	2-10-2020	09-10-2020	150x150x150	22500	455	15.37	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore.- 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 10-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	03-10-2020
Sample Type	R C C Wall Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	10-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	452	14.52	14.51
2	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	450	14.65	
3	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	455	14.35	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP. Bangalore - 92

AARTN ASSOCIATES DATE BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 10-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	03-10-2020
Sample Type	R C C Wall Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	10-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	452	14.1	14.23
2	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	450	14.25	
3	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	455	14.35	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP. Bangalore - 92

AARTN ASSOCIATES
DATE
BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 10-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	03-10-2020
Sample Type	R C C Wall Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	10-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	452	14.1	14.53
2	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	450	14.25	
3	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	455	15.23	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 10-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	03-10-2020
Sample Type	R C C Wall Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	10-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	452	14.25	14.72
2	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	450	14.67	
3	R C C Raft Culvert	M20	03-10-2020	10-10-2020	150x150x150	22500	455	15.23	

Remarks :

AARTN ASSOCIATES DATF BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 11-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	04-10-2020
Sample Type	R C C Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	11-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	452	14.56	14.95
2	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	450	14.98	
3	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	455	15.32	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES DATE BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 11-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	04-10-2020
Sample Type	R C C Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	11-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	452	14.56	14.63
2	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	450	14.98	
3	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	455	14.35	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP. Bangalore - 92

AARTN ASSOCIATES DATE No. BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 11-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	04-10-2020
Sample Type	R C C Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	11-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	452	14.32	14.44
2	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	450	14.65	
3	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	455	14.35	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 11-10-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	04-10-2020
Sample Type	R C C Culvert
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	11-10-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	452	14.32	14.44
2	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	450	14.65	
3	R C C Raft Culvert	M20	04-10-2020	11-10-2020	150x150x150	22500	455	14.35	

Remarks :

Asst. Executive Engineer

AARTN ASSOCIATES DATE No. BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 17-09-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	20-08-2020
Sample Type	C.C Drain Raft Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 28 Days Compressive Strength
Date of Test	17-09-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in K.N	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	699	24.57	24.82
2	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	689	24.65	
3	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	708	25.23	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP. Bangalore - 92

AARTN ASSOCIATES DATE BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 17-09-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	20-08-2020
Sample Type	C.C Drain Raft Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 28 Days Compressive Strength
Date of Test	17-09-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Weight of the sample	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	kg	KN	N/mm^2	N/mm^2
1	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	8.92	692	25.17	24.90
2	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	9.07	703	24.87	
3	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	9.13	689	24.65	

Remarks :

AE

Asst. Executive Engineer
Project Division
[illegible]
BE[illegible]alore - 92

AARTN ASSOCIATES DATE BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 17-09-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	20-08-2020
Sample Type	C.C Drain Raft Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 28 Days Compressive Strength
Date of Test	17-09-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in K.N	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	699	25.14	25.33
2	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	689	25.63	
3	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	708	25.23	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP Bangalore - 64

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 17-09-2020
Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06	
Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reiference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	20-08-2020
Sample Type	C.C Drain Raft Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 28 Days Compressive Strength
Date of Test	17-09-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in K.N	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	699	25.14	24.77
2	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	689	24.63	
3	C.C Drain Raft Concrete	M20	20-08-2020	17-09-2020	150x150x150	22500	708	24.54	

Remarks :

AE

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore - 92

AARTN ASSOCIATES
DATE
BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 18-09-2020

Name of Work : Comprehensive Development of Hegdenagar East Side cross roads and Shabarinagar Cross road in Ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. V Chandrappa
Customer Reference	EE(Project)YNK Zone/WO/163/2019-20
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	21-08-2020
Sample Type	C.C Drain Raft Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 28 Days Compressive Strength
Date of Test	18-09-2020
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	C.C Drain Raft Concrete	M20	21-08-2020	18-09-2020	150x150x150	22500	690	24.48	25.02
2	C.C Drain Raft Concrete	M20	21-08-2020	18-09-2020	150x150x150	22500	700	24.97	
3	C.C Drain Raft Concrete	M20	21-08-2020	18-09-2020	150x150x150	22500	687	25.61	

Remarks :

AE

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP. Bangalore - 92

AARTN ASSOCIATES BANGALORE
DATE